LABORATORY SERVICES
1026 Blossom Hill Road
San Jose, CA 95123-1103
Santa Clara Valley Water District

Annual Treated Water Quality Report

Title 22 Regulated and Unregulated Compounds

Start: 1/1/2018 End: 12/31/2018

PARAMETER	PWTP TREATED				RWTP TREATED				STWTP TREATED				DLR	MCL	Units
	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4			

Organic Chemicals: Primary Standards - Mandatory Health-Related Standards

PARAMETER	PWTP Q1	PWTP Q2	PWTP Q3	PWTP Q4	RWTP Q1	RWTP Q2	RWTP Q3	RWTP Q4	STWTP Q1	STWTP Q2	STWTP Q3	STWTP Q4	DLR	MCL	Units
1,1,1-Trichloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	200	ug/L
1,1,2,2-Tetrachloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	1	ug/L
1,1,2-Trichloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	5	ug/L
1,1-Dichloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	5	ug/L
1,1-Dichloroethylene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	6	ug/L
1,2,4-Trichlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	5	ug/L
1,2-Dichlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	600	ug/L
1,2-Dichloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	0.5	ug/L
1,2-Dichloropropane	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	5	ug/L
1,3-Dichloropropene (Total)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	0.5	ug/L
1,4-Dichlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	5	ug/L
2,4,5-TP (SILVEX)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1	50	ug/L
2,4-D	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	10	70	ug/L
Alachlor	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1	2	ug/L
Atrazine	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	1	ug/L
Bentazon (BASAGRAN)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2	18	ug/L
Benzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	1	ug/L
Benzo (A) Pyrene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1	0.2	ug/L
Carbon Tetrachloride	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	0.5	ug/L
Chlordane	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	0.1	0.1	ug/L
cis-1,2-Dichloroethylene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	6	ug/L
cis-1,3-Dichloropropene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	0.5	ug/L
Dalapon	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	10	200	ug/L
Di (2-ethylhexyl) Adipate	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5	400	ug/L
Dibromochloropropane	ND	ND	ND	ND	NT	ND	ND	ND	ND	ND	ND	ND	0.01	0.2	ug/L
Dichloromethane (Methylene Chloride)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	5	ug/L
Diethylhexylphthalate	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3	4	ug/L
Dinoseb (DNBP)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2	7	ug/L
Dioxin (2,3,7,8-TCDD)	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	5	30	pg/L
Diquat	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	4	20	ug/L
Endothall	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	45	100	ug/L
Endrin	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	0.1	2	ug/L
Ethylbenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	300	ug/L
Ethylene Dibromide (EDB)	ND	ND	ND	ND	NT	ND	ND	ND	ND	ND	ND	ND	0.02	0.05	ug/L
Glyphosate	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	25	700	ug/L
Heptachlor	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	0.01	0.01	ug/L
Heptachlor Epoxide	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	0.01	0.01	ug/L
Hexachlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	1	ug/L
Hexachlorocyclopentadiene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1	50	ug/L
Lindane (Gamma-BHC)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.2	0.2	ug/L
Methoxychlor	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	10	30	ug/L
Methyl tert-Butyl Ether (MTBE)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3	13	ug/L
Molinate (ORDRAM)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2	20	ug/L

LABORATORY SERVICES
1026 Blossom Hill Road
San Jose, CA 95123-1103

Santa Clara Valley Water District

Annual Treated Water Quality Report

Title 22 Regulated and Unregulated Compounds

Start: 1/1/2018 End: 12/31/2018

PARAMETER	PWTP TREATED				RWTP TREATED				STWTP TREATED				DLR	MCL	Units
	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4			
Monochlorobenzene (Chlorobenzene)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	70	ug/L
Pentachlorophenol	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.2	1	ug/L
Picloram	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1	500	ug/L
Simazine (PRINCEP)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1	4	ug/L
Styrene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	100	ug/L
Tetrachloroethylene (PCE)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	5	ug/L
Thiobencarb (BOLERO)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1	70	ug/L
Toluene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	150	ug/L
Total PCB's (as DCB)	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	0.5	0.5	ug/L
Total-Xylene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	1750	ug/L
Toxaphene	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	1	3	ug/L
trans-1,2-Dichloroethylene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	10	ug/L
trans-1,3-Dichloropropene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	0.5	ug/L
Trichloroethylene (TCE)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	5	ug/L
Trichlorofluoromethane (FREON 11)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5	150	ug/L
Trichlorotrifluoroethane (FREON 113)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	10	1200	ug/L
Vinyl Chloride	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	0.5	ug/L

Inorganic Chemicals: Primary Standards - Mandatory Health-Related Standards

Aluminum	ND	ND	80	56	ND	ND	ND	ND	ND	ND	ND	ND	50	1000	ug/L
Antimony	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6	6	ug/L
Arsenic	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2	10	ug/L
Barium	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	100	1000	ug/L
Beryllium	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1	4	ug/L
Cadmium	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1	5	ug/L
Chromium, Total	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	10	50	ug/L
Cyanide	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	100	150	ug/L
Fluoride	0.65	0.72	0.64	0.73	ND	ND	ND	ND	0.65	0.72	0.64	0.68	0.1	2	mg/L
Mercury	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1	2	ug/L
Nickel	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	10	100	ug/L
Nitrate (as N)	0.7	ND	ND	ND	0.7	ND	ND	ND	0.6	0.4	ND	ND	0.4	10	mg/L
Nitrate + Nitrite (as N)	0.70	ND	ND	NT	0.70	ND	ND	NT	0.60	0.4	ND	NT	0.4	10	mg/L
Nitrite (as N)	ND	ND	ND	NT	ND	ND	ND	NT	ND	ND	ND	NT	0.4	1	mg/L
Perchlorate	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4	6	ug/L
Selenium	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5	50	ug/L
Thallium	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1	2	ug/L

Inorganic Chemicals: Secondary Standards - Aesthetic Standards

Apparent Color	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	NS	15	Color Units
Chloride	64	36	54	63	62	42	62	70	73	74	74	80	NS	500	mg/L
Copper	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	50	1000	ug/L
Foaming Agents (MBAS)	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	NS	0.5	mg/L
Iron	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	100	300	ug/L
Lead	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5	15	ug/L

Annual Treated Water Quality Report

Title 22 Regulated and Unregulated Compounds

Start: 1/1/2018 End: 12/31/2018

PARAMETER	PWTP TREATED				RWTP TREATED				STWTP TREATED				DLR	MCL	Units
	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4			
Manganese	ND	ND	34.9	ND	ND	ND	ND	ND	ND	ND	ND	ND	20	50	ug/L
Odor T.O.N.	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1	3	T.O.N.
pH	7.7	8.0	7.8	7.8	7.8	7.8	7.7	7.8	7.9	7.9	7.5	7.8	NS	NS	pH units
Silver	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	10	100	ug/L
Specific Conductance (E.C.)	533	280	363	517	506	340	423	511	483	463	476	508	NS	2200	umhos/cm
Sulfate	80.0	37.7	25.7	55.3	75.3	55.2	48.6	53.5	45.2	43.0	51.7	46.7	0.5	500	mg/L
Total Dissolved Solids	291	192	212	274	266	226	268	270	272	292	286	284	NS	1000	mg/L
True Color	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	NS	NS	Color Units
Turbidity	ND	0.12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1	5	NTU
Zinc	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	50	5000	ug/L

Organic Chemicals: Unregulated - Additional Constituents Analyzed

1,1,1,2-Tetrachloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
1,1-Dichloropropene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
1,2,3-Trichlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
1,2,4-Trimethylbenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
1,3,5-Trimethylbenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
1,3-Dichlorobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
1,3-Dichloropropane	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
2,2-Dichloropropane	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
2-Chlorotoluene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
4-Chlorotoluene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
Acifluorfen	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	NS	NS	ug/L
Aldrin	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	0.075	NS	ug/L
Bromobenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
Bromochloromethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
Bromodichloroacetic Acid	2.4	2.1	1.5	3.0	6.0	4.4	3.8	6.0	2.5	ND	ND	ND	1	NS	ug/L
Bromomethane (Methyl Bromide)	ND	ND	NT	ND	ND	ND	NT	ND	ND	ND	NT	ND	0.5	NS	ug/L
Chloroethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
Chloromethane (Methyl Chloride)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
Dibromomethane	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
Dicamba (BANVEL)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.5	NS	ug/L
Dichlorodifluoromethane (FREON 12)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
Dieldrin	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	0.02	NS	ug/L
Diisopropyl Ether (DIPE)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3	NS	ug/L
Ethyl tert-Butyl Ether (ETBE)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3	NS	ug/L
Hexachlorobutadiene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
Isopropylbenzene (Cumene)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
Naphthalene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
n-Butylbenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
N-Nitrosodiethylamine	<2	<2	<2	<2	<2	<2	<2	<2	NT	<2	<2	<2	NS	NS	ng/L
N-Nitrosodimethylamine	<2	<2	<2	<2	<2	<2	<2	<2	NT	<2	<2	<2	NS	NS	ng/L
N-Nitrosodi-n-butylamine	<2	<2	<2	<2	<2	<2	<2	<2	NT	<2	<2	<2	NS	NS	ng/L
N-Nitrosodi-n-propylamine	<2	<2	<2	<2	<2	<2	<2	<2	NT	<2	<2	<2	NS	NS	ng/L

LABORATORY SERVICES
1026 Blossom Hill Road
San Jose, CA 95123-1103

Santa Clara Valley Water District

Annual Treated Water Quality Report

Title 22 Regulated and Unregulated Compounds

Start: 1/1/2018 End: 12/31/2018

PARAMETER	PWTP TREATED				RWTP TREATED				STWTP TREATED				DLR	MCL	Units
	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4			
N-Nitrosomethylethylamine	<2	<2	<2	<2	<2	<2	<2	<2	NT	<2	<2	<2	NS	NS	ng/L
N-Nitrosopiperidine	<2	<2	<2	<2	<2	<2	<2	<2	NT	<2	<2	<2	NS	NS	ng/L
N-Nitrosopyrrolidine	<2	<2	<2	<2	<2	<2	<2	<2	NT	<2	<2	<2	NS	NS	ng/L
n-propylbenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
Paraquat	NT	NT	ND	NT	NT	NT	ND	NT	NT	NT	ND	NT	20	NS	ug/L
p-Isopropyltoluene	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	NS	NS	ug/L
sec-Butylbenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
tert-Amyl Methyl Ether (TAME)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3	NS	ug/L
tert-Butyl Alcohol (TBA)	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2	NS	ug/L
tert-Butylbenzene	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.5	NS	ug/L
Total Organic Carbon	2.90	1.78	1.67	2.40	2.50	1.50	1.47	1.77	2.17	2.10	1.67	1.60	0.3	NS	mg/L

Inorganic Chemicals: Unregulated - Additional Constituents Analyzed

PARAMETER	PWTP TREATED				RWTP TREATED				STWTP TREATED				DLR	MCL	Units
	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4			
Ammonia, Free (as NH3-N)	0.09	0.10	0.13	0.13	0.08	0.07	0.09	0.13	0.09	0.18	0.12	0.16	NS	NS	mg/L
Ammonia, Total (as NH3-N)	0.71	0.68	0.74	0.69	0.52	0.49	0.51	0.50	0.55	0.51	0.65	0.72	NS	NS	mg/L
Bicarbonate Alkalinity (as CaCO3)	66	42	68	101	68	45	69	88	65	65	70	70	NS	NS	mg/L
Bicarbonate Alkalinity (as HCO3)	81	51	83	123	83	55	84	108	80	79	86	86	NS	NS	mg/L
Boron	197	138	ND	142	205	134	112	138	139	141	140	135	100	NS	ug/L
Bromide	0.09	<0.05	0.06	0.08	0.06	<0.05	<0.05	0.08	0.13	0.08	0.07	0.13	NS	NS	mg/L
Calcium	22.6	10.9	12.1	25.0	23.8	12.1	13.3	22.5	18.1	17.5	15.0	19.3	NS	NS	mg/L
Calcium as CaCO3	56.5	27.2	30.3	62.4	59.6	30.3	33.2	56.3	45.3	43.7	37.5	48.2	NS	NS	mg/L
Carbonate Alkalinity (as CaCO3)	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	NS	NS	mg/L
Carbonate Alkalinity (as CO3)	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	NS	NS	mg/L
Chlorate	43	88	110	120	87	65	67	88	280	95	190	110	20	NS	ug/L
Chromium, Hexavalent	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1	NS	ug/L
Cobalt	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	NS	NS	ug/L
Hardness (as CaCO3)	111	51	64	126	117	58	68	114	94	87	76	99	NS	NS	mg/L
Hydroxide Alkalinity (as CaCO3)	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	NS	NS	mg/L
Hydroxide Alkalinity (as OH)	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	NS	NS	mg/L
Lithium	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	NS	NS	ug/L
Magnesium	13.3	5.9	8.3	15.6	14.0	6.7	8.5	14.1	10.8	10.6	9.3	12.4	NS	NS	mg/L
Molybdenum	1.6	1.2	<1	1.1	1.6	1.1	1.1	1.1	<1	1.3	1.3	1.2	NS	NS	ug/L
Phosphate	1.23	1.15	1.12	1.20	1.55	1.15	1.09	1.27	1.42	1.13	1.18	1.22	NS	NS	mg/L
Potassium	3.1	1.5	1.8	3.2	3.4	1.8	2.1	3.3	3.2	3.0	2.5	3.7	NS	NS	mg/L
Silica	13.7	10.3	11.0	10.0	13.8	9.8	10.6	10.3	13.5	12.6	11.9	12.7	NS	NS	mg/L
Sodium	63.6	31.2	32.9	51.4	64.7	38.5	40.4	54.2	52.8	52.8	44.9	63.4	NS	NS	mg/L
Temperature	13	19	24	20	12	19	22	19	15	19	23	20	NS	NS	Deg. C
Total Alkalinity (as CaCO3)	66	42	68	101	68	45	69	88	65	65	70	70	NS	NS	mg/L
Vanadium	ND	ND	3.9	ND	ND	ND	ND	ND	ND	ND	ND	ND	3	NS	ug/L

PARAMETER	PWTP TREATED				RWTP TREATED				STWTP TREATED				DLR	MCL	Units
	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4			

Q1 = 1st Quarter.
Q2 = 2nd Quarter.
Q3 = 3rd Quarter.
Q4 = 4th Quarter.
NT = Not Tested
ND = Not Detected
NR = Not Reported at or above the DLR
DLR = Detection Limit for Reporting
MCL = Maximum Contaminant Level
ug/L = Micrograms Per Liter
NS = No Standard
STWTP = Santa Teresa Water Treatment Plant
PWTP = Penitencia Water Treatment Plant
RWTP = Rinconada Water Treatment Plant
mg/L = Milligrams Per Liter
NTU = Nephelometric Turbidity Units
umhos/cm = Micromhos Per Centimeter
Deg. C = Degree in Celsius